

**TEST REPORT**

Rendered to:

**DAYTON TECHNOLOGIES, L.L.C.**


**SERIES/MODEL: 2000 XO**

**TYPE: Vinyl Sliding Glass Door**

<b>Title of Test</b>	<b>Results</b>
Rating	SGD-R50 72 x 80
Overall Design Pressure	50.0 psf
Air Infiltration	0.12 cfm/ft <sup>2</sup>
Water Resistance	7.50 psf
Structural Test Pressure	75.0 psf
Forced Entry Resistance	Passed Level 10

Reference should be made to Report No. 07-30211.01 for complete test specimen description and data.

For ARCHITECTURAL TESTING, INC.:

  
Larry D. Mankin, Technician

LDM/jb