



**AAMA/WDMA/CSA 101/I.S.2/A440-05 AND
ANSI/AAMA/NWDA 101/I.S.2-97
TEST REPORT**

Rendered to:

DECEUNINCK NORTH AMERICA, LLC

**SERIES/MODEL: 200.200 Patio Door
PRODUCT TYPE: PVC Sliding Glass Door**

Title	Summary of Results	
	Test Specimen #1	Test Specimen #2
AAMA/WDMA/CSA 101/I.S.2/A440-05 Rating	SD-R20 2426 x 2426 (96 x 96)	SD-R30 1816 x 2019 (72 x 80)
ANSI/AAMA/NWDA 101/I.S.2-97 Rating	SGD-R20 96 x 96	SGD-R30 72 x 80
Design Pressure	±960 Pa (±20.06 psf)	±1440 Pa (±30.09 psf)
Operating Force (in motion)	40 N (9 lbf)	N/A
Air Infiltration	0.71 L/s/m ² (0.14 cfm/ft ²)	0.51 L/s/m ² (0.10 cfm/ft ²)
Water Penetration Resistance Test Pressure	260 Pa (5.43 psf)	N/A
Uniform Load Structural Test Pressure	±Pa (±30.09 psf)	±2160 Pa (±45.14 psf)
Forced Entry Resistance	Grade 10	N/A

Test Completion Date: 08/28/08

Reference must be made to Report No. 85671.01-501-47, dated 10/06/08 for complete test specimen description and data.